

PRE BID QUERIES AND THEIR REPLY- LIGHT FIXTURE - PACKAGE 6A

8th Oct 2018

DEVELOPMENT OF PERMANENT CAMPUS FOR NALANDA UNIVERSITY AT RAJGIR, BIHAR STATE
PRE BID QUERIES REPLY- LIGHT FIXTURE - PACKAGE 6A

Clause, Section and Volume	Item Description	As per Bid Document	Prospective Bidder's Queries	Reply to the Query
PROSPECTIVE BIDDER : 01				
NIT 6A	Summary of Scope of work	This tender is invited for Supplying and Safe keeping of Light Fixture for Various buildings including procurement of fixture and safe keeping till handing over to client or installing agency with complete scope at permanent campus of Nalanda University (NU) Project. The INSTALLATION OF LIGHTFIXTURER SHALL BE DONE BY THE CLIENT THROUGH EXISTING CONTRACTOR (OTHER THAN HIGHMAST) of the project	Kindly confirm scope of the following expenses (tenderer / bidder / erection contractor) a. Cost of space to built up store inside university campus b. Cost to statutory clearance b. Type of store temporary / permanent c. Cost of transportation of material from store to site d. Cost of loading and unloading e . Cost of security f. Additional cost in case of project overrun more than 12 months	All shall be Scope of the Contractor. Safe Keeping of the Fixture shall be done till final handing over as per NIT document.
NIT 6A		3. The time allowed for carrying out the Work shall 12 months from the date of initiation as defined in Schedule –F or from the first date of handing over of the Site, whichever is later.	Kindly confirm maximum time limit for handing over of total site .	NIT Conditions shall Prevail. 12 months to complete the supply and testing works. Also Safekeeping till handing over to the installation contractor as per NIT Conditions.
Page 13 - NIT 6A	SOLVENCY CERTIFICATE		Bank only issue SOLVENCY CERTIFICATE in their approved format , request to allow submission of SOLVENCY CERTIFICATE as per standard format of the bank .	NIT Conditions shall Prevail.
Page 64 - NIT 6A	Milestone of Works	Time duration 12 Months	Request to furnish timeline for 1. Safe keeping of the material 2. Approval by consultant after submission of technical data sheet.	NIT Conditions shall prevail. Approval By consultant may be completed in 3 days if all the documents submitted are correct and as required.
Page 70 - NIT 6A	Defects Liability Period	60 months from completion of the project as a whole.	Kindly clarify term " completion of project " 1. After supply as per scope of work 2. Completion of installation and commissioning after handing over of the project . However installation is not in the scope of the bidder hence handingover of project is not under bidders control. So Defect Liability will start from supply of material.	Completion of work shall be completion of scope mentioned in the NIT Document.
Clause 7 : Payment, Page 95 of 207		15% On successful handing over to client for beneficial use	Handing over shall be completed after installation activity by contractor appointed by Purchaser. In view of same release this 15% payment after supply of material within 30 days or kindly complete handing over activity within 30 days from material supply.	NIT Conditions shall prevail
Page 9 - TS 6A	High Mast Pole system	Sample to be approved,	Sample for pole and High mast are not possible to submit , however GA drawing / Data sheet will be furnished for approval .	Sample for Highmast pole is not required. GTPs & GA to be provided with ample details alongwith an installation photograph.
Page 10 - TS 6A	Lux Design Sheet	Tenderer has to submit the lux design sheet	Considering desired lux level as mentioned in tender document , Illumination design with lux level plotting will be submitted by bidder . CAD layout to be provided by the tenderer.	Will be made available at adequet stage
Page 9 - TS 6A	Spoecial notes	Successful bidder to compley points mentioned in " Special notes "	Kindly confirm.	NIT to be cosndiered here
Price Schedule	Sr. No. 1 to 21 : Supply and Testing of LED Fixtures	As per scope of work, Bidder Scope is limited to Supply and safe keeping. Testing will not be part of bidder scope.	Kindly confirm. IF tensting is in bidder scope then inform us Modality and Scope related to testing.	Random type tests at factory / works & store as per IS are considered here under head of Testing.
NIT Page 95 to 207	clause7: Payment, Page 95 to 207	15% of Successful Handing over to client for Beneficial use.	Handing over shall be completed after installation activity by contractor appointed by Purchaser. In view of same release this 15% payment after supply of material within 30 days or kindly complete handing over activity within 30 days from material supply.	NIT Conditions Shall prevail.
Price Schedule	Scope of Work	Scope of Work	Kindly confirm that, whether we can quote tender for High Masts, Poles, Stadium Masts, Flood Lights and street lights only.	It is a percentage rate tender. Tenderer cannot quote for part work.

Clause, Section and Volume	Item Description	As per Bid Document	Prospective Bidder's Queries	Reply to the Query
Price Schedule	Fixture Color	Fixture Color	Grey Colour finished indoor fixtures are available with specific makes only. So request you to accept LED fixtures with finished colour as per manufacturer standard.	NIT Conditions shall prevail.
General			In tender desired Lux level is specified for various applications. But in BOQ, quantity and wattage are already freezed for fixtures. Kindly clarify our scope is design based or we have to follow tender luminaires wattage and quantities. If we have quote design based tender, then kindly arrange lux level criteria for out door / stadium lighting along with drawings of area/ground to be illuminated.	Lux calculation sheets to be provided by the tenderer as per NIT document.
NIT document: TS6A page 7, 8	NIT document: TS6A page 7, 8	control systems like , DALI, RF control, E- security.	We request you to elaborate scope related to control system and their integration.	NIT conditions shall prevail.
Price Schedule	Price Schedule	Quantity of items.	Quantity mentioned under Price Schedule are not whole number and are with fractions. Kindly check and confirm.	All numbers shall be nearest whole numbers.
Price Schedule	Price Schedule	Sr. No. 21, Pole and Bracket Details	Request you to arrange pole drawing and bracket arm length.	Pole and Bracket for this item is not in the tender scope. Please refer Corrigendum 1.
NAME OF BIDDER : PROSPECTIVE BIDDER 02				
NIT - Commercial & Scope			It is requested to place the P.O. on WIPRO authorized Dealer in the event of finalizing the Order on WIPRO. Complacence regarding all the pre-qualification criteria, technical & Commercial aspects will be done by WIPRO only.	Not acceptable. If order is placed with Wipro then Wipro has to complete the work directly. P.O shall be placed to Wipro.
NIT - Commercial & Scope			Clarity required regarding demonstration of samples.	Please refer Corrigendum 1.
NIT - Commercial & Scope			Deployment of manpower and scope during Defect Liability / warrantee period.	NIT conditions shall prevail.
NIT - Commercial & Scope			Clarity on Payment terms. Mainly on 15% payment after successful handing over to the client for beneficiary use.	NIT conditions shall prevail.
TS - Make List			Approval of WIPRO Brand in High Mast requested.	NIT conditions shall prevail.
TS - Make List			Please incorporate LED make of CITIZEN & LUMILEDS along with the existing make.	NIT conditions shall prevail.
BOQ			Execution scope is also mentioned in the tender documents . But as it is a complete supply tender. High mast Installation also mentioned in the scope which needs to be removed.	Scope shall be as specified in tender, High Mast jobs are given as EPC complete.
BOQ			CCT is varying in the tender description and your proposed Cat reference no mentioned in BOQ for most of the line items.	Tender BOQ to be followed, Basket of Fixture is provided only to get idea of requirement of aesthetics.
BOQ			Sr. No. 10 - Cat reference number is mentioned is IP20 as the product is Indoor. Specifications is asking for IP65. Need clarifications.	Tender BOQ to be followed, Basket of Fixture is provided only to get idea of requirement of aesthetics.
BOQ			Sr. No. 12 Pls. correct the product code for color tunable to LM34-361-XXX-2765 + RF module.	Tender BOQ to be followed, Basket of Fixture is provided only to get idea of requirement of aesthetics.
BOQ			Sr. No. 14 wattage (9W) mentioned for Step light is much higher, It should be around 2.5 W.	This is to be considered as 5 to 7 watt in place of 9watt.
BOQ			Sr. No. 15 Change the code for extruded aluminum to LB12-131-XXX-65-08	Tender BOQ to be followed, Basket of Fixture is provided only to get idea of requirement of aesthetics.
BOQ			Group control for Post Tops with feeder panel level control for auto ON/OFF from centralized software & Individual level control for Street lights with dimming suggested.	NIT conditions shall prevail.
BOQ			Pls. propose Laura base system along with Zigbee protocol.	NIT conditions shall prevail.