


**Ref:- No. NU/NIT/UIC/146/2015-16/1280Re\_1/31/42**

**Date: 12th April 2016**

**Sub: Tender Notice No. NU/NIT/UIC/2015-16/1280Re\_1/3 date: 08th April 2016-  
Clarification to the prospective bidders.**

With reference to the Limited Tender Notice No. NU/NIT/UIC/2015-16/1280Re\_1/31 dated 08<sup>th</sup> April 2016 for Supply Installation Testing and Commissioning of 2x315KVA transformer along with extension of HT line for Nalanda University's Interim Campus at Rajgir, Bihar. In order to maintain the more clarity over the item's specification, it is to clarify that under the said tender Annexure-I, Schedule of Quantity, Sl. NO. 28- "PVC cable for LT" is indicated which means LT as an output of 315 KVA transformer hence it shall be read as "AL PVC armoured cable for LT side of 315 KVA DTR should have size of 3.5 core, 300 sq meter, (25 meter of length for each run, 2 run for each DTR output) . For any technical clarification and site visit, bidders may contact to **Ms. Swati Krishna, JE(E), NU @ Mob: +91-9102011241 / Ph. No: 06112 255330.**

All the other terms and conditions of tender does remain unchanged. The tender documents along with this notice are available at University website: <http://www.nalandauniv.edu.in/tenders/> and also at <http://eprocure.gov.in/cppp> - with tender id 2016\_NU\_87017\_1 or 102449\_1.



**Er. Manoj Kumar**  
**Asst. Engineer (Elect.)**

- Copy to:**
1. (As per list Attached)
  2. Notice Board(NU)
  3. Website of NU & CPPP
  4. Notice board of the DM, O/o The DM, Nalanda, Bihar Sharif.
  5. Notice board of the SDM, O/o The SDM Rajgir, District Nalanda
  6. Notice board of CPWD, Patna
  7. Notice board of PWD, Patna
  8. Notice Board(Nagar Panchayat), O/o Executive officer, Nagar Panchayat , Rajgir
  9. Notice board of EEE(Supply), SBPDCL, Rajgir